

Office Of The District Fire Officer
Karnataka Fire And
Emergency Services
Koppal District Koppal - 583231

APPENDIX-XII

FIRE SAFETY CERTIFICATE

No. 27/DFO/KPL/CC/2025


Dated: 08/04/2025

Certified that the **Haripriya English Medium HPS Kushtagi** (name of the building premises) at **Koppal Main Road kushtagi** (address) comprised of ground floor basement(s) and First floor (upper floors) owned/ occupied by **Haripriya Education Foundation Trust ®** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **26/03/2025** (date of inspection) in the presence of **Mr.Shivappa Talli** (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes to X (X/XII) With effect from 03/04/2025 for a period of 1 year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Fire fighting installation
2. 3000 Litre Water Sources
3. 3HP Water Pressure Motor
4. Down Comer and Fire Alarm

Issued on **08/04/2025** (date of issue) at **Koppal** (place) by

*Strike out whichever is not applicable.

 08/04/2025

**District Fire Officer
Karnataka Fire And
Emergency Services**

Signature with Seal **Koppal District Koppal - 583231**

Name : **H. K. Ramappa**

Designation : **DFO**

Name & Address of Department/Office: **Koppal**

To

**Haripriya Education Foundation
Trust ®**

**Haripriya English Medium HPS
Kushtagi-583277**

(Name & Address of the Institution)